



**City of Safford  
Reclaimed Water Pond  
June 8, 2022**

EXPIRES 6/30/25

**Addendum No. 5**

This addendum pertains to the entire set of bid documents and to the entire plan set and shall take precedence over any conflicting information contained therein.

Amendments

1. Bid Opening

The Bid Opening Date shall be changed to be Thursday, June 16, 2022 at 2:00 PM.

2. Clay Liner

The clay liner material shall have a seepage rate of 4,000 gal/acre/day (or less) which is equivalent to a permeability of  $4.81 \times 10^{-7}$  cm/sec.